TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

Sub: Administrative approval for erection of 132/33 kV Substation at Remalle / Rangannagudem in Krishna district along with connected 132 kV & 33 kV lines – Accorded.

T.O.O (CE-Construction-I) Ms. No.191

APSPDCL have proposed for erection of 132/33 kV substation at Remalle / Rangannagudem in Krishna district to meet increased load on 33/11 kV substations and also to reduce 33 kV line losses. Load flow studies were conducted by the Chief Engineer (Power Systems) for erection of above 132/33 kV substation and it is observed that the 132/33 kV substation at Remalle / Rangannagudem in Krishna district is essential to reduce the overloaded 33 kV feeders and 33 kV substations and to improve voltage conditions and quality & reliability of power supply in the area.

Chief Engineer/Construction-I formulated a scheme for erection of a 132/33 kV substation at Remalle / Rangannagudem in Krishna district along with connecting 132 kV and 33 kV lines and has proposed to pose the scheme to M/s. Power Finance Corporation Ltd., New Delhi / M/s. Rural Electrification Corporation Limited, New Delhi / other funding agencies for sanction of loan.

After careful consideration, APTRANSCO accords approval for the above scheme at a total cost of **Rs. 2618.25 Lakhs** as per the break up indicated below:

ABSTRACT OF THE ESTIMATE

| SI.No | Description | Qty | Unit | RATE PER UNIT Rs.LAKHS | AMOUNT IN Rs.LAKHS |
|-------|--|-----|-------|------------------------------|-----------------------|
| 1 | 132/33 kV Substation at Remalle / Rangannagudem with 1 x 31.5 + 1 x 16 (released) MVA PTR Capacity (Radial) | No | 1 | 824.00 | 824.00 |
| 2 | 132kV DC/SC line from Gunadala 220/132 kV Substation to the proposed 132/33 kV Remalle / Rangannagudem Substation | KM | 44.00 | 38.00 | 1672.00 |
| 3 | 132 kV Bay extension at Gunadala 220/132 kV Substation. | No | 1 | 70.00 | 70.00 |
| 4 | 33 kV line with 100 Sqmm AAAC | KM | 14.50 | 2.50 | 36.25 |
| 5 | Communication facility(PLCC) | No | 1 | 16.00 | 16.00 |
| | Total cost of works | | | | 2618.25 |

(**) Estimate with 1 x16 MVA released Power Transformer.

Or Say Rs. 2618.25 Lakhs

Dated:16.08.2011

The scheme will be executed with financial assistance from M/s. Power Finance Corporation Ltd., New Delhi / M/s Rural Electrification Corporation Limited, New Delhi / other funding agencies and with APTRANSCO funding in case full loan is not sanctioned by M/s. Power Finance Corporation Ltd., New Delhi / M/s Rural Electrification Corporation Limited / other funding agencies. The cost of the 33 kV lines at Item No.4 of the above Abstract of Estimate will be borne by APSPDCL.

The Chief Engineer / Construction-II is hereby authorized to take up the above works after investment approval is obtained from APERC, and financial tie-up is completed. This authorization is issued with the concurrence of Director (Finance & Revenue) vide U.O. No. 3002 Dated. 4.08,2011.

"In exercise of the powers conferred by G.O. Ms. No. 115 dated 07.10.2003 of Government of Andhra Pradesh, APTRANSCO or their authorized representatives shall have the powers that the Telegraphic Authority possesses under the provision of the Indian Telegraph Act 1885 (13 of 1885) for placing of any wires, poles, towers etc., for Transmission of electricity or for the purpose of telephonic or telegraphic communication facility necessary for the proper coordination of the works of the APTRANSCO.

BY ORDER AND IN THE NAME OF TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

Sd/DIRECTOR/ TRANSMISSION

Tο

The Chief Engineer/Construction-I/Vidyut Soudha/Hyderabad.

Copy to:

The Chairman & Managing Director/APSPDCL.

The Executive Director / Planning, RAC & Reforms/V.S./Hyd

The Chief Engineer/Construction-II/Vidyut Soudha/Hyderabad

The Chief Engineer /Power Systems

The Chief Engineer/EA,O, RE&IT

The Chief Engineer/ Transmission

The Chief Engineer /Lift Irrigation

The Chief Engineer/ Vijayawada Zone/ Vijayawada

The Chief Engineer/Telecom/VS/Hyderabad

FA & CCA (CF)/Vidyut Soudha/Hyderabad

FA & CCA (A&E)/Vidvut Soudha/Hvderabad

The Superintending Engineer/TL&SS/ Vijayawada

The Superintending Engineer/TLC/ Vijayawada

The Superintending Engineer/Op/APSPDCL/ Vijayawada

The Superintending Engineer/PM-I/Construction-I/VS/Hyd.

The Superintending Engineer/PM-II/Construction-II/VS/Hyderabad.

Personal Secretary to the Chairman & Managing Director

Personal Secretary to the Joint Managing Director (Distribution), HRD

Personal Secretary to the Joint Managing Director / Comml, IPC, Reforms, RA&IT

Personal Secretary to the Joint Managing Director/Vigilance & Security,

Personal Secretary to the Director/Finance & Revenue,

Personal Secretary to Director/Projects

FORWARDED BY ORDER

Personal Secretary to Director/Grid Operation

DE (T) to Director/Transmission

DE3 of SE/PM- II O/o CE/Construction-II

D:\T.O.Os\T.O.O 2010-11\Meerjapuram (Remalle) TOO.doc