

BY SPEED POST



TRANSMISSION CORPORATION OF TELANGANA LIMITED

Website: www.tgtransco.com. GST No. 36AAFCT0166J1Z9 CIN No. U40102TG2014SGC094248

From:

The Chief Engineer,
P&MM, TGTransco,
Vidyut Soudha,
Hyderabad– 500 082.
e-mail: ce.pmm@tgtransco.com

To

M/s.GR Power Switchgear Ltd.,
Kotamma Bhavan,
Plot 27/B, IDA, Phase-IV,
Jeedimetla, Hyderabad – 500 055
Tel: 040-23095589.
Mail ID:info@grpowers.net.

SAP PO.No.4500003390/Web. PO No.1041/CE(P&MM)/SE(P&MM)/DE11/F:TGPMM11-18/2025/132KV Isolators/D.No.132/2025, Dt:15.12.2025.

Sirs,

Sub: Tender Specification No. TGPMM11-18/2025- Supply of 1 No. 132KV, 800A Isolators with ES & 35 Nos. 132KV, 800A Isolators w/o ES –Detailed Purchase Order – Issued – Regarding.

Ref: 1. Tender Specification No. TGPMM11-18/2025.
2. Your offer against Tender Specification No. TGPMM11-18/2025 on e-platform.
3. LOI No.CE(P&MM)/SE(P&MM)/DE11/TGPMM11-18/2025/F:132KV Isolators/D.No.119/2025,Dt:21.11.2025.
4. Lr.No.GRPS/WO-4594/TGTRANSCO/38029/2025, dt:27.11.2025

* * *

I, acting for and on behalf of and by the order and direction of TRANSMISSION CORPORATION OF TELANGANA LIMITED, accept your offer, vide ref(2), for supply of 132KV, 800A Isolators with ES & 35 Nos. 132KV, 800A Isolators w/o ES detailed in clause (2) below, with the terms and conditions as per the Tender Specification No TGPMM11-18/2025. This Purchase Order is issued in confirmation of the Letter of Intent issued vide ref (3) cited, accepted by you vide ref (4) cited.

1. Scope of Contract:

This contract relates to the supply of the 132kV Isolator metallics 800A with & without ES detailed in clause–2 below and covers design, manufacture, testing before dispatch and delivery free at destination substations/ stores (FADS) as detailed in this order.

2. Schedule of Equipment & Prices:

Supply of the following 132kV class, 3 pole outdoor type, Horizontal Double Break Isolator with/without Earth Switch 3 phases 50c/s and fault level of 40KA per second, auxiliary equipment, all fittings & accessories, clamps& connectors, bolts & nuts, other essentials including terminal connectors and components/switches/modules/contacts required to be provided with Isolators for interfacing with monitoring, automation system etc., conforming to the latest issue of IS:9921 and as per the Technical Specification.

(a) The price break-up details are as below:

SCHEDULE OF MATERIALS & PRICES:

| Sl. No. | Description | Amount in Rs. | |
|--|---|----------------------------------|---------------------------------|
| | | 132KV, 800A Isolators with ES | 132KV, 800A Isolators w/o ES |
| | | (HSN Code: 85353090) | |
| 1 | Unit Ex-Works | 2,28,800.00 | 1,45,800.00 |
| 2 | Unit Packing & forwarding | — | — |
| 3 | Unit Freight | 7,800.00 | 7,800.00 |
| 4 | Unit Insurance | 1,183.00 | 768.00 |
| 5 | Total Taxable Unit Price | 2,37,783.00 | 1,54,368.00 |
| 6 | CGST@9% + SGST@9% on (Ex-Works + Freight+ Insurance) | 42,800.94 | 27,786.24 |
| 7 | Unit FADS Price | 2,80,583.94 | 1,82,154.24 |
| 8 | Quantity (Nos.) | 1 | 35 |
| 9 | Total Amount | 2,80,583.94 | 63,75,398.40 |
| 10 | Grand Total | 66,55,982.34 | |
| Rupees Sixty Six Lakh Fifty Five Thousand Nine hundred Eighty Two and Thirty Four Paisa only | | | |

(b) The prices indicated above are **FIRM**.

(c) The price is inclusive of all incidental charges such as Packing, Forwarding, Handling, Loading, Unloading and other incidentals and it is your responsibility for insurance, transportation and delivery including unloading, stacking of the materials at destination site/stores.

(d) Freight and Insurance will be reimbursed on submission of documentary proofs only. The Insurance shall cover transit and storage for 45 days at destination site/stores.

(e) The dispatch of equipment is by road only. The transit insurance shall be at least for an amount equal to 100% of the cost of the goods and include storage cover for 45 days at stores/site.

(f) It is to note that the prices are with the present rate of CGST@9% + SGST@9% on the total of Ex- Works, Freight and Insurance.

(g) TCS at prevailing rates is applicable on any payment made, if company's aggregate sales consideration during the relevant financial year exceeds Rs.50 Lakhs and total sales, gross receipts or total turnover including GST if any exceeds Rs.10 Crores in the financial year immediately preceding the financial year of subject sales. The payment of TCS shall be subject to furnishing of necessary documents. The stipulated conditions are to be verified by the DDOs while processing the bills. The PAN No. of TGTRANSCO is AAFCT0166J.

(h) The supervision of erection of the above equipment substation site shall be done free of cost.

(i) TGTransco shall have the right to vary the ordered quantity by $\pm 50\%$ at any time during the execution of the order.

- (j) If any payment is made erroneously, TGTransco reserves the right to recover the same from your future bills/BGs.
- (l) e-Invoicing (IRN) is mandatory for businesses where aggregate turnover exceeds 5 Crores in a Financial Year.

3. Delivery:

| | |
|---------------------------------------|---|
| 132KV, 800A Isolators with ES -1No. | To supply total quantity within 3 months from the date of LOI |
| 132KV, 800A Isolators w/o ES -35 Nos. | |

4. Performance Security:

Performance Security shall be furnished in the name of TGTransco for an amount of 10% of the contract value (i.e.) Rs.6,65,599.00 (Rupees Six Lakhs Sixty Five Thousand Five Hundred and Ninety Nine only) for proper fulfillment of the contract, which will include the warranty period and completion of performance obligations including Warranty obligations. The Performance security will cover 60 days beyond the date of completion of performance obligations including Warranty obligations.

In the event of any correction of defects or replacement of defective material during the warranty period, the warranty for the corrected/replaced material will be extended to a further period of 12 months and the Performance Bank Guarantee for proportionate value will be extended 60 days over and above the extended warranty period. The proceeds of the performance security will be payable to the Purchaser as compensation for any loss resulting from the Supplier's failure to complete its obligations under the Contract.

The performance security will be...

- (a) A Bank Guarantee issued by State Bank of India or its associate Banks/Nationalised Banks acceptable to the Purchaser, in the form provided in the bidding documents.
- (b) A banker's cheque or crossed DD or Pay Order payable at the head quarter of the Purchaser in favour of the Pay officer drawn on any scheduled Bank.

It is entirely your responsibility to extend the validity of this Bank Guarantee to cover the period of guarantee well before its expiry.

5. Guaranteed Technical Particulars: The Guaranteed Technical Particulars are enclosed to this Purchase Order. The drawings shall be furnished immediately for approval.

6. Payment:

- a) 100% payment will be arranged through PFC/REC/Bank/TGTransco funds within 45 days reckoned from the check measurement date in Form-13.

b) For payment through Real Time Gross Settlement (RTGS) the details of your Bank Account are as follows:

| | | |
|--------|------------------|--|
| (i) | Name of the Bank | State Bank of India |
| (ii) | Branch Address | Shapurnagar Branch, APIIC Colony, Opp Sub Station, IDA, Jeedimetla, Hyderabad – 500 055. |
| (iii) | Branch Code | 20400 |
| (iv) | City | Hyderabad |
| (v) | Account No. | 40798962392 |
| (vi) | MICR Code | 500002356 |
| (vii) | IFSC Code | SBIN0020400 |
| (viii) | PAN No. | AAACG7476M |
| (ix) | GST No. | 36AAACG7476M1Z2 |

c) The 100% payment mentioned above is subject to submission of performance security by the supplier as per clause (4) above.

d) The supplier should invariably submit acceptance and routine test certificates and other documents the purchaser specifies before the dispatch is made so that they can be checked and approved well in advance.

e) The performance guarantee shall be furnished on a stamp paper of value Rs.100/-. The Bank Guarantee will be extended if required suitably in accordance with the provisions of Performance Security clause of the specification.

f) If the supplier has received any over payments by oversight or if any amounts are due to the TGTransco due to any other reasons, when it is not possible to recover such amounts under the contract resulting out of this specification, TGTransco reserves the right to collect the same from any other amount due to the supplier and / or Bank Guarantees given by the company due to or with TGTransco.

g) When the supplier does not at any time, fulfill his obligations in replacing / rectifying etc. the damaged / defective materials in part or whole promptly to the satisfaction of the TGTransco officers, TGTransco reserves the right not to accept the bills against subsequent dispatches made by the supplier and only the supplier will be responsible for any demurrages, wharfages or damage occurring to the consignments so dispatched.

h) Any incidental charge such as stamp duty, bank charges etc., shall be to the Supplier's account and any charges in relation there to shall not be included in the bills submitted to TGTransco's Paying Officer through Banks.

i) All payments will be made in non-convertible Indian Rupees.

j) The Bank details as above are final and shall not be revoked under any circumstances.

7. RESPONSIBILITY OF THE SUPPLIER FOR LOSS/DAMAGE:

- a) The supplier is responsible for the safe delivery of the goods in good condition at the destination. He should acquaint himself of the conditions obtaining for handling and transport of the goods to destination and shall include and provide for security and protective packing of the goods so as to avoid damage in transit.
- b) External damages or shortages that are *prima facie* the results of rough handling in transit or due to defective packing will be intimated within a fortnight of the receipt of the materials. Internal defects, damages or shortages of any internal parts which cannot ordinarily be detected on a superficial visual examination will be intimated subsequently.

In either case, the defective or damaged materials should be replaced by the supplier free of cost to the TGTransco. If no steps are taken within 15 days of receipt of intimation of defects or such other reasonable time as the TGTransco may deem proper to afford, TGTransco may without prejudice to its other rights and remedies cause to be repaired or rectified the defective material or replace the same and recover the expenditure incurred there for from the deposit such as Earnest Money, Security and Performance or other monies available with TGTransco or by resorting to legal action.

- c) For the purpose of any legal construction, the material shall be deemed to pass into TGTransco's ownership only at the final destination where they are delivered and accepted.

8. PENALTY FOR LATE DELIVERY:

- a) The delivery period as per agreed delivery schedule shall be deemed to be the essence of the contract. In case of delay in delivery of materials beyond the agreed delivery schedule or to perform the services within the period specified in the contract whatever be the reason the TGTransco may at its option, demand and recover from the supplier from the contract price, as liquidated damages, a sum equivalent to 0.5% per week on the undelivered portion subject to a maximum of 5% of total value of contract.
- b) For penalty, the number of days of delay would be rounded off to the nearest week and interest calculated accordingly.
- c) Equipment which is not of acceptable quality (or) not confirming to specification would be deemed to be not delivered.
- d) The penalty specified will be levied and would be adjusted against subsequent pending bills.

- e) The check measurement date in Form-13 i.e., the date of receipt of equipment at the destination stores in good condition will be taken as date of delivery.

9. FORCE MAJEURE:

- a) The Supplier will not be liable for forfeiture of its performance security, penalty for late delivery or termination for default if and to the extent that it's delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.
- b) For the purpose of this clause 'Force Majeure' means an event beyond the control of the Supplier and not involving the Suppliers' fault or negligence and not foreseeable. Such events may include but are not restricted to wars or revolutions, fires, floods, epidemics, earth quakes, Tsunami, quarantine restrictions and freight embargoes.
- c) If the Force Majeure situation arises, the supplier will promptly notify the Purchaser in writing of such condition and the cause thereof. Unless otherwise directed by the Purchaser in writing, the Supplier will continue to perform its obligations under the Contract as far as is reasonably possible, and will seek all reasonable alternative means for performance not prevented by the Force Majeure event.

10. TERMINATION FOR DEFAULT :

- a) The Purchaser without prejudice to any other remedy for breach of Contract, by written notices of default sent to the Supplier, may terminate this Contract in whole or part:
 - i) If the Supplier fails to deliver any or all of the Materials/equipment within the period(s) specified in the Contract, or within any extension thereof granted by the Purchaser.
 - ii) If the supplier fails to perform any other obligations under the contract.
 - iii) If the Supplier, in the judgment of the Purchaser has engaged in corrupt or fraudulent practices in competing for or in executing the Contract.
- b) In the event the Purchaser terminates the Contract in whole or in part, the Purchaser may procure, upon such terms and in such manner, as it deems appropriate, Materials/equipment or services similar to those undelivered and the Supplier will be liable to the Purchaser for any excess costs for such similar Materials/equipment or Services. However, the Supplier will continue performance of the Contract to the extent not terminated.

11. TERMINATION FOR CONVENIENCE:

- a) The Purchaser, by written notice sent to the supplier may terminate the contract, in whole or in part, at any time for its convenience. The notice of termination is for the Purchaser's convenience, the extent to which performance of the supplier under the contract is terminated, and date upon which termination becomes effective.
- b) However the materials/equipment that are complete and ready for shipment within thirty (30) days after the supplier's receipt of notice of termination will be accepted by the Purchaser at the contract terms and prices.

12. TERMINATION FOR INSOLVENCY:

The Purchaser may at any time terminate the Contract by giving written notice to the Supplier if the Supplier becomes bankrupt or otherwise insolvent. In this event, termination will be without compensation to the supplier, provided that such termination will not prejudice or not affect any right of action or remedy, which has accrued or will accrue thereafter to the Purchaser.

13. WARRANTY:

The equipment/ material shall be guaranteed for satisfactory performance for a period of 18 months from the date of receipt of material/equipment at destination site/ TLC stores in good condition against defects proved to be due to faulty design of material/ workmanship. If during this period, any of the material is found defective they shall be repaired or replaced by you free of all costs to the TGTransco. To and fro freight charges shall also be to your account only.

14. TAXES:

Taxes as indicated in the price schedule at paragraph (2) are applicable. You shall agree, that if, at any time, any GST reported to have been paid has not been paid, or a lesser amount has been paid, or on subsequent adjudication or appeal or revision it is decided that a lesser amount is payable, you shall refund such amounts irrespective of time lag.

15. STATUATORY VARIATIONS:

Any variation up or down in statutory levy or new levies introduced after signing of the contract under this specification will be to the account of TGTransco, provided that in cases where delivery schedule is not adhered to by the supplier and there are upward variation/ revision after the agreed delivered date, the supplier will bear the impact of such levies and if there is downward variation / revision the TGTransco will be given credit to that extent. Statutory variation if any allowed, it is allowed only once during delivery period, i.e. at the time of delivery of goods at factory. In case of sub-vendor items, taxes & duties are inclusive in tender price and no statutory variation is applicable.

In cases where the bidder assumes less tax rates and become lowest, upward variation of taxes will not be considered. In case of the bought out items for which the prices are quoted all inclusive of taxes, statutory variation shall not be applicable.

16. DISPATCH INSTRUCTIONS:

The dispatch instructions for the equipment will be furnished separately on satisfactory scrutiny of acceptance test certificates. The prices indicated in clause (2) above shall remain unaltered whatever be the destination.

17. INSPECTION:

After completion of manufacture of the equipment/ material, routine tests shall be performed as per relevant standards and requisite copies of test certificates shall be furnished to the purchaser. Various components of the equipment shall be routine tested in accordance with approved standards and manufacture standards.

As soon as the material/ equipment are ready the supplier will duly send intimation to TGTransco by post/fax and carry out the tests in the presence of the representative of TGTransco. The Supplier shall give at least 15 days advance intimation to enable the Purchaser to depute his representative for witnessing acceptance and routine tests. All charges in connection with inspection shall be borne by the supplier.

The equipment should not be dispatched without final inspection of the tests, approval of test certificates and issue of specific dispatch instructions or specific waiver thereof from this office. The equipment shall reach the destination store/site within three weeks of issue of Dispatch Instructions.

18. CONTRACT DRAWINGS:

The detailed drawing of the equipment were approved vide reference (6) cited . Approval by TGTransco to the supplier's drawings shall not relieve the supplier of his responsibility for correctness thereof or from results arising out of error or omission therein or from any obligation or liability under the contract. Any supplementary drawings necessary to permit the complete design of the installation prior to receiving the equipment shall also be supplied. Within two weeks of approval, six sets of all approved drawings and soft copy of drawings shall be furnished. One set of drawings and instruction manuals along with soft copy shall be sent along with each equipment at the time of dispatch. Copies of the drawings and manuals shall also be sent to other offices as indicated below.

| | | |
|------------------------------|---|--|
| Consignee | : | One set of approved drawings per consignee |
| Concerned Executive Engineer | : | Two Sets |
| To this office | : | Six sets. |

19. ERECTION, OPERATION & MAINTENANCE MANUALS:

Erection, operation and maintenance manuals along with soft copy shall be supplied as per distributions given below giving detailed instructions with illustrations along with the equipment. They shall contain clear recommended schedule of maintenance for the guidance of the operating staff. Any items requiring the special attention of the operation engineer should be highlighted.

| | | |
|------------------------------|---|-------------------------|
| Consignee | : | One set per consignment |
| Concerned Executive Engineer | : | Two sets |
| To this office | : | Six sets |

These shall be sent to the Divisional Engineers / Executive Engineers concerned.

20. COMPLETENESS OF CONTRACT:

All minor accessories that are normally necessary for satisfactory and efficient operation of the equipment shall be supplied by you free of cost to the TGTransco whether these are specifically mentioned or not in the specification, your tender schedules or in this purchase order and the equipment shall be complete in itself.

21. GENERAL CONDITIONS OF CONTRACT:

Except in so far as it is provided otherwise in this contract, you shall abide by the terms and conditions appended to the specification. Except as specifically accepted in this order the terms and conditions mentioned in your quotation under reference are not accepted.

22. RISK:

The risk in the property is entirely yours till the goods are received in good condition at the destination.

23. PACKING:

Each of the material/equipment shall be securely packed separately in such a manner as to withstand rough handling during rail and road transit up to site and as per latest IS/BSS/IEC.

24. TESTS & TEST CERTIFICATES:

All routine tests in accordance with relevant ISS/BSS/IEC specifications shall be conducted on the equipment. You shall intimate this office at least 15 days in advance as to the date when you propose to conduct the acceptance tests for deputing TGTransco's representative to witness the tests. Three copies of the test certificates containing the results of all the acceptance tests along with routine tests carried out shall be furnished for approval. The test certificates shall be submitted immediately after the tests are conducted and got approved before the equipment is dispatched.

25. MATERIAL & WORKMANSHIP:

All the materials shall be of the best class and shall be capable of satisfactory operation in the tropics under service conditions without distortion or deterioration. No welding or filling or plugging of defective parts shall be permitted, unless otherwise specified they shall conform to the requirement of the appropriate Indian, British or American standards (where a standard specification covering the material in question has not been published the standards of the American society for testing of materials should be followed).

The entire design and construction shall be capable of withstanding the several stresses likely to occur in actual services and of resisting rough handling during transport.

26. INSURANCE:

The Materials / equipment supplied under the Contract will be fully insured against loss or damage incidental to manufacture or acquisition, transportation and delivery and also storage for 45 days at destination stores/site.

The insurance will be in an amount equal to 100% FADS value of material/ equipment on all risks basis. The policy will have a provision for extension to cover further storage if necessary at destination stores / site at TGTransco cost. The insurance beneficiary shall be TGTransco.

The supplier shall a) Initiate and pursue insurance claim till settlement, and b) Promptly arrange for repair and or replacement of any damaged items in full irrespective of settlement of insurance claim by the under writers, c) All costs because of insurance liabilities covered under the contract will be to supplier's account. The supplier shall provide the Purchaser with a copy of all insurance policies and documents taken out by him in pursuance of 'Contract'. Such copies of documents shall be submitted to the purchaser immediately after such insurance coverage. The supplier shall also inform the Purchaser in writing at least sixty (60) days in advance, regarding the expiry, cancellation and /or change in any of such documents and ensure revalidation/renewal etc., as may be necessary well in time.

The risks that are to be covered under the insurance shall be comprehensive and shall include but not limited to, the loss or damage in transit, storage, due to theft, pilferage, riot, civil commotion, weather conditions, accident of all kinds, fire, flood, war risk (during ocean transportation) bad or rough handling etc., The scope of such insurance shall cover the entire contract value.

All costs on account of insurance liabilities covered under the contract will be on supplier's account and will be deemed to have been included in the bid price.

The documentary proof towards insurance shall be submitted while transporting the material/equipment to the purchasers destination.

27. INTERCHANGEABILITY:

All similar equipment and removable parts of similar equipment shall be interchangeable with each other.

28. SPARES:

You shall supply any spares required for the equipment that will be supplied under this order, whenever called upon to do so at fair prices and at the TGTransco's standard terms of payment within a period not exceeding the deliveries accepted therein.

29. PROGRESS REPORTS:

You shall furnish the program of works and progress reports on the manufacture of equipment to this office every month in triplicate till the supplies are completed.

30. CORRESPONDENCE:

- a) Your acknowledgement of this order and all correspondence of general or technical nature shall be addressed to the Chief Engineer/P&MM, TGTransco, Vidyut Soudha, Hyderabad –500 082.
- b) All correspondence regarding dispatches, payments and any other field matters shall be addressed to the concerned paying officer. Copies of such correspondence shall be marked to the concerned Superintending Engineer and to the Chief Engineer/P&MM, TGTransco, Vidyut Soudha, Hyderabad –500 082. Copies of the correspondence regarding payments should also be marked to the FA &CCA/(Audit & Expenditure), TGTransco, Vidyut Soudha, Hyderabad –500 082.

31. JURISDICTION:

All and any disputes or differences arising out of or touching this order shall be decided only by courts or tribunals situated in Hyderabad or Secunderabad cities. No suit or other legal proceedings shall be instituted elsewhere.

32. SUPERVISION OF ERECTION, TESTING AND COMMISSIONING:

You have to provide services of qualified personnel for supervision of erection, testing at site and commissioning of the equipment wherever required. The above services should be provided free of Cost as per the bid specification.

31. ACKNOWLEDGEMENT:

Please acknowledge the receipt of this purchase order with your confirmation of its acceptance by you and the extra copy enclosed may please be returned with your signature in token of your acceptance.

Yours faithfully,

Sd/-
Chief Engineer/P&MM
(Acting for and on behalf of TGTRANSCO)

WE ACCEPT THE TERMS AND CONDITIONS OF THIS PURCHASE ORDER

SIGNATURE OF THE CONTRACTOR
WITH SEAL AND DATE

Copies to:

The FA &CCA/(Audit & Expenditure) / TGTransco /Vidyut Soudha/Hyderabad.
The Chief Engineer/Transmission/TGTransco/Vidyut Soudha/Hyderabad.*
The Chief Engineer/Metro Zone/ TGTransco /Erragadda/Hyderabad.*
The Superintending Engineer/Transmission/ TGTransco /Vidyut Soudha/Hyderabad.*
The Superintending Engineer/Quality Control/ TGTransco /Vidyut Soudha/Hyderabad.*
The SAO/Pay & accounts/ TGTransco /Vidyut Soudha/Hyderabad along with Form-40.
The Superintending Engineer/OMC/Metro-Central/ TGTransco /Hyderabad
The SAO/Metro-Central/TGTransco /Hyderabad
The Divisional Engineer/Transmission &Stores/Metro/Erragadda/ Hyderabad, 500 045.
The AEE/Construction Stores/ TGTransco /Erragadda/Hyderabad.

* Copy of this PO is available on <http://tgto.telangana.gov.in/>

* This order is placed against the indents indicated below:

| Sl. No. | UO dated: | Description of work | 132kV, 800A Isolator W/o ES | 132kV, 800A Isolator With ES |
|---------------------------|--|--|-----------------------------|------------------------------|
| 1 | U.O No. CE(Tr)/ SE(Tr)/DE-SS/ ADE2/ F.4685/D.No.599/23, Dt:14.11.2023 | Erection of 2nd set of 132kV Bus PT in grid connected 18 Nos. Substation. (PR.No.1300001251) (PR No. 1300001252) (PR.No.1300001253) (PR.No.1300001254) (PR.No.1300001255) (PR.No.1300001256) (PR.No.1300001257) (PR.No.1300001258) (PR.No.1300001259) (PR.No.1300001260) | 18 | — |
| 2 | UO.No.CE(Tr)/SE(Tr)/DE-SS/ ADE/ F.Bansawad /D.No.26724, Dt:25.06.2024 (PR received on U.O.D.No.61/24, Dt:19.09.2024) | Augmentation of PTR 220/132kV SS Banswada (PR NO. 1100000305) | 1 | — |
| 3 | UO.No.CE(Tr)/SE(Tr)/DE-SS/ ADE/ F.wanaparthy/ D.No.260/24, Dt:25.06.2024 (PR recd. on U.O D.No.60/24, Dt:19.09.2024) | Augmentation at 220/132kV SS Wanaparthy. (PR No. 1100000335) | 3 | — |
| 4 | UO.No.CE(Tr)/SE(Tr)/DE-SS/ ADE/ F.Yeddu-mailaram/ D.No367/24, Dt:24.07.2024 (PR recd. on U.O D.No.58/24, Dt:19.09.2024) | Augmentation at 220/132 kV SS Yeddu-mailaram. (PR No. 1100000334) | 5 | 1 |
| 5 | UO.No.CE(Tr)/SE(Tr)/DE-(Tr)/ ADE-Tr/ F.No.D.No.272/24, Dt:13.02.2025 | Aug of PTR at 220/132kV Fabcity SS (PR No: 1100000316) | 2 | — |
| 6 | UO.No.CE(Tr)/SE(Tr)/DE-(Tr)/ ADE-Tr/ F.No.D.No.274/24, Dt:14.02.2025 | Aug of PTR at 220/132kV Nagarkunool SS (PR No: 1100000400) | 2 | — |
| 7 | UO.No.CE(Tr)/SE(Tr)/ DE-(Tr)/ ADE-Tr/ F.No.D.No.275/24, Dt:14.02.2025 | 220/132kV Kosigi SS (PR.No.1100001522) | 2 | — |
| | | 220/132kV Miyapur SS (PR.No.1100001524) | 2 | — |
| Total Qty. in Nos. | | | 35 | 1 |

GUARANTEED TECHNICAL PARTICULARS

| Sl.No. | Description | Unit | 132kV, 800A Isolator with ES | 132kV, 800A Isolator w/o ES |
|--------|--|--------|--|-----------------------------|
| 1) | Manufacturer's Name & Address of manufacture & GSTN Number | | GR Power Switchgear ltd., "Kotamma Bhavan" Plot No. 27/B, I.D.A., IV Phase, Jeedimetla, Hyderabad-500 055, INDIA GST Regn. No.36AACG7476M1Z2 | |
| 2) | Type Designation & HSN (8 Digit code) | | Center Post Rotating Horizontal Double Break- "DB"- HSN Code: 85353090 | |
| 3) | Applicable Standards | | IS: 9921(Part I to V)/ IEC-62271-102 | |
| 4) | Rated Voltage | kV | 132 | |
| 5) | Rated Frequency | Hz | 50 | |
| 6) | Outdoor/ Indoor | kV | Outdoor | |
| 7) | Whether all three poles are ganged together mechanically/electrically | | Mechanically ganged operation | |
| 8) | Rated Normal Current | | 800A | |
| a) | Under Normal conditions (as per IS/ IEC) | A | | |
| b) | Under Site conditions | A | | |
| 9) | Rated short time withstand current for 1 sec. for Isolator & Earth switch | KA rms | 40 KA rms | |
| 10) | Rated peak withstand short circuit current for Isolator & Earth switch | KAp | 100 KAp | |
| 11) | Rated short circuit making current | kA | NA | |
| 12) | Rated magnetising current/ capacitive current make/ break capacity at 0.15% p.f. | A | 0.7A at 0.15pf | |
| 13) | Temperature rise over ambient temperature 50 deg.C at site corresponding to | | | |
| a) | Max. continuous current | °C | Within the limits of values as specified in table 4 of (Page No.2) of IS:9921 (Part II) of 1982 derated to 50°C | |
| b) | Short time current | °C | | |
| 14) | Rated Insulation Levels | | | |
| a) | 1.2/50 μ sec. lightning impulse withstand voltage (+ve or -ve polarity) | | | |
| | i) to earth | kVp | 650 | |
| | ii) across the open Isolator | | | |
| | - One terminal lightning impulse | kVp | 750 | |
| | - opposite terminal power frequency | kVp | NA | |
| b) | 250/2500 μ sec. switching impulse withstand voltage: | | | |
| | i) to earth | kVp | NA | |
| | ii) across the open Isolator | | | |
| | - One terminal switching impulse | kVp | NA | |
| | - opposite terminal power frequency | kVp | NA | |
| c) | One minute power frequency withstand voltage | | | |
| | i) to earth | kV | 275 | |
| | ii) across the terminal of open Isolator | kV | 315 | |
| 15) | Corona extinction voltage | kV | 105 | |

| Sl.No. | Description | Unit | 132kV, 800A Isolator with ES | 132kV, 800A Isolator w/o ES |
|--------|---|--------------------|---|-----------------------------|
| 16) | Maximum Radio Interference Voltage at 0.5 MHz, 1.0 MHz, 1.5 MHz & 2 MHz at kV (μ V & corresponding kV-rms) | μ V | <500 μ V | |
| 17) | Rated mechanical terminal load | | | |
| a) | Longitudinal (or straight) | N | 800 | |
| b) | Transverse (or cross) | N | 200 | |
| c) | Min Cantilever strength (Upright) | kg | Insulator are not in scope | |
| 18) | Total Operating Time | | | |
| a) | Opening time | sec | Less than 12Secs. | |
| b) | Closing time | sec | Less than 12Secs. | |
| 19) | Main Contacts (Fixed & Moving) of Isolator Switch & Earth switch | | | |
| a) | Type | | Reverse loop pressure relieving type | |
| b) | Material | | Hard drawn Electrolytic copper | |
| c) | Whether contacts are Silver plated | | Yes | |
| d) | Thickness of silver coating | microns | 25 Microns | |
| e) | Contact Area | mm ² | min 500 | |
| f) | Contact pressure | Kg/mm ² | medium pressure | |
| g) | Current density (at minimum cross section of switch blade) | | | |
| i) | Moving blade | A/mm ² | 1.6 | |
| ii) | Terminal Pad | A/mm ² | 0.8 | |
| iii) | Contacts | A/mm ² | 1.6 | |
| iv) | Terminal Connectors | A/ mm ² | 1 | |
| h) | Fixed Contacts: | | | |
| | Cross-sectional area | mm ² | 32 x 4 x 2 x 2 = 512 sq.mm | |
| | Moving Blades: | | | |
| | ii) Cross-sectional area | mm ² | OD-38 mm, ID- 28 mm, Length- 2240mm ; 518 Sq.mm | |
| i) | Number of operations which the Isolator can withstand without deterioration of contacts | Nos. | 1000 (min.) | |
| j) | Jumper Plate/ Aluminium Flat with current density | mm ² | 100 x 12 = 1200 mm | |
| 20) | Auxiliary contacts | | | |
| a) | Main Isolator | | | |
| | i) Total number of 'NO' (for purchaser's use) | Nos. | 12 | |
| | ii) Total number of 'NC' (for purchaser's use) | Nos. | 12 | |
| | iii) Rate Voltage | V | 220V DC | |
| | iv) Rated continuous current | A | 10A | |
| | v) Rated breaking current | A | 2A DC with time constant of not less than 20 ms | |
| b) | Earth switch | | | |
| | i) Total number of 'NO' (for purchaser's use) | Nos. | 6 | NA |
| | ii) Total number of 'NC' (for purchaser's use) | Nos. | 6 | NA |
| | iii) Rate Voltage | V | 220V DC | |
| | iv) Rated continuous current | A | 10A | |

| Sl.No. | Description | Unit | 132kV, 800A Isolator with ES | 132kV, 800A Isolator w/o ES |
|--------|---|------|--|--------------------------------|
| | v) Rated breaking current | A | 2A DC with time constant of not less than 20 ms | |
| c) | Whether arcing contacts provided, If so, type and material used | | Yes, make before break after- GI Rod | |
| 21) | Minimum clearance in air: | | | |
| a) | Phase to phase clearance | mm | 3000 | |
| b) | Phase to Ground clearance | mm | Equal to the dry arcing distance of the insulator selected (3625) | |
| c) | Between phases when Isolator is open: | mm | 2135 | |
| d) | Center to Center distance of outer distance of outer poles in each phase(min) | mm | 2500 (min.) | |
| 22) | Base Channel | mm | 125×65 mm ; Length: 2500 mm | |
| 23) | Bearings - | | | |
| a) | Type of bearings | | Ball bearing | |
| b) | Location of bearings | | Below the rotating post insulators. One at the top and one at the bottom of the bearing housing. | |
| c) | Type of lubricant for bearings | | Grease lubricated for life time | |
| 24) | Terminal Clamp & Connectors | | | |
| a) | Suitable for | | Twin Moose | |
| b) | Manufacturer's Name | | Klemmen/ Legion or its equivalent make | |
| c) | Applicable Standard | | IS:5561 | |
| d) | Material | | | |
| i | Clamp body | | Aluminium Alloy, LM-6 | |
| ii | Bolts & Nuts | | MS Hot dip galvanised | |
| iii | Spring washers | | Hot dip galvanised | |
| e) | Rated Current | A | 800 | |
| f) | Rated terminal Load | kg | within the limits of values as specified in IS:5561 | |
| g) | Weight of clamp complete with hardware | kg | 3 Kgs (approx.) | |
| h) | Radio interference voltage | µV | <500 µV | |
| i) | Corona extinction voltage | kV | 105 | |
| 25) | Operating Mechanism | | | |
| a) | Name & address of Manufacturer | | GR Power Switchgear Ltd., | |
| b) | Type of operating mechanism | | Manual operated for main switch & Earth Switch | |
| c) | Whether separate operating mechanism provided for operation of Isolator pole and earth switch | | Yes | |
| d) | Electrical operation | | | |
| i) | Motor type (AC/ DC) | | NA | |
| ii) | Applicable standard | | NA | |
| iii) | Ratings – Voltage, Current, HP | | | |
| iv) | Type of enclosure and, method of cooling | | NA | |
| v) | Power required for closing and opening operation | W | NA | |
| vi) | Running time of motor for closing operation | Sec | NA | |
| vii) | Control supply for motor & power | V, W | NA | |

| Sl.No. | Description | Unit | 132kV, 800A Isolator with ES | 132kV, 800A Isolator w/o ES |
|--------|---|------|--|-----------------------------|
| | consumption | | | |
| e) | Type of manual operating mechanism for Isolator pole & earth switch | | Main switch: Manual Earth switch :Manual | |
| f) | Force required to operate | | 30 kgm. | |
| g) | Whether padlocking are included as per the specification | | Yes | |
| h) | Type of manual device | | Torsional | |
| i) | Weight of operating mechanism | kg | 35kgs. (approx.) | |
| 26) | Type of interlocking between Isolator and Earthing switch | | | |
| a) | Resistance of operating and interlocking coils | kΩ | 1.885kΩ for operating coil, 6.19kΩ for interlocking coil. | |
| b) | Details of following interlocks provided as per specification: | | | |
| i) | mechanical interlock between Isolator and earth switch | | Yes | |
| ii) | electrical interlock between Isolator and earth switch | | Yes | |
| iii) | electrical interlocking in association with Circuit Breaker | | Yes | |
| iv) | electrical interlock to bring back all three poles to open position in case any pole fails to close within specified time | | Since the isolators are required with mechanically ganged operation it is not applicable. It is applicable only isolators are required with Electricity ganged | |
| v) | provision to cut-off supply to motor during manual operation and provision for de-coupling the motor | | Yes | |
| vi) | electrical scheme to provide remote alarm for pole discrepancy | | Since the isolators are required with mechanically ganged operation it is not applicable. It is applicable only isolators are required with Electricity ganged | |
| vii) | Arrangement provided to prevent electrical or manual operation unless interlocks are satisfied | | Yes | |
| 27) | Control Cabinet/ Marshalling box/ MOM Panel | | | |
| a) | Name & address of Manufacturer | | GR Power Switchgear Ltd., Hyd | |
| b) | Applicable standard | | IS:5039/ IS:8623; IEC:60439 | |
| c) | Sheet thickness Top/ bottom/ side/ back/ door leaf | mm | 3mm thick Aluminium Sheet | |
| d) | Degree of protection provided | | IP-55 | |
| e) | Colour of finish paint – | | | |
| | i) Out side | | Light grey (shade No.631 of IS: 5) Glossy white | |
| | ii) In side | | Inside: Glossy white | |
| f) | Control Wiring | | | |
| | i) Current & Voltage ratings | A, V | 16A, 1100V | 16A, 1100V |
| | ii) Control Wiring – Size & material of conductor | | 2.5 Sq.mm copper | 2.5 Sq.mm copper |

| Sl.No. | Description | Unit | 132kV, 800A Isolator with ES | 132kV, 800A Isolator w/o ES |
|--------|--|---------------------|---|-----------------------------|
| g) | Terminal Blocks | | | |
| | i) Name & address of manufacturer | | Elmex/ Connectwel/ Techink or its equivalent make | |
| | ii) Current & Voltage ratings | A, V | 25A, 1100V | |
| h) | Space heater rating at 240 V | W | 80 Watts | |
| i) | Provision of lock with keys | Yes/ No | Yes | |
| j) | Dimensioned drawing (External & Internal) enclosed | Yes/ No | Yes, Enclosed | |
| k) | Control Cabinet/ Marshalling box internal lighting & Door switch for controlling | | Yes | |
| l) | Weight | kg | 35 kgs. (approx.) | |
| m) | Plinth mounted/ structure mounted | | Structure mounted | |
| 28) | a) Tandem Pipe | | | |
| | i) Size | | 32mm | |
| | ii) Class | | Class B | |
| | iii) Material | | GI Pipe | |
| | iv) Applicable standard | | IS:1239(Part I), 1990& IS:4736, 1986 | |
| | v) weight of zinc | gm/Sq.mm | 450 gm/ Sq.mm | |
| | b) Down Pipe | | | |
| | i) Size (Internal & External dia.) | mm | 50mm | |
| | ii) Class | | Class B | |
| | iii) Material | | GI Pipe | |
| | iv) Applicable standard | | IS:1239(Part I), 1990& IS:4736, 1986 | |
| | v) weight of zinc | gm/ mm ² | 450gm/Sq mm | |

Sd/-

Chief Engineer/P&MM