

TGTRANSCO Transmission Losses for the month of November-2024					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TGGENCO	TOTAL	1854.15			
	TGGENCO-THERMAL	1397.79	TGSPDCL	4307.21	
	TGGENCO-HYDEL	456.36	TGNPDCL	1409.23	
C.T.U			Total Discom	5716.44	
	CTU(Injection at TG-Periphery)	2859.35			
CPPs	TOTAL	71.72			
	132kv Laxmi Tulasi	0.00			
	132 kV Orient Cement	0.07			
	220KV Navabharat Energy India Ltd (NBEIL)-I	26.97			
	220KV Navabharat Energy India Ltd (NBEIL)-II	26.90			
	132KV Penna Power-I	0.00			
	132KV Penna Power-II	0.00			
	132KV Deccan Cements	0.00			
	132 kV Madhucon	0.00			
	132kv SCCL 30MW Solar Plant (Manuguru)	3.06			
	220 kV Heavy Water Plant#1	0.00			
	220 kV Heavy Water Plant#2	0.85			
	132kv PSR Green Power Proj. pvt. Ltd.	0.00			
	220KV RFCL	0.00			
	132 kV Kesoram	0.05			
	132 kV Sitapuram Power Limited	0.12			
	132 kV Anjaini Port Land Cement	0.00			
	132kv SCCL 37 MW Solar Plant (Sitharampatnam)	4.88			
	132 kV Sitaramapatnam - NBVL (NBFA)#1	0.18			
	132 kV Sitaramapatnam - NBVL (NBFA)#2	0.57			
	132 kV Sitaramapatnam - BPBL	0.01			
	132KV Shalivahana(MSW) Green Energy Ltd.,	0.00			
	132kv Krishnaveni Sugars Ltd	4.42			
	132 kV My Home Industries Limited	0.03			
	132 kV ICL (Rassi Cements)	0.00			
	132 kV Bharat Electronics Ltd. (solar)	0.00			
	132kv SCCL Solar Power Plant (Yellandu)	3.60			
Non-Conventional (132 & 220 kV PDs)	Total	397.36			
	ACME Medak Solar energy Pvt. Ltd.	7.51			
	ACME Nizamabad Solar Energy Pvt. Ltd	7.54			
	ACME PV Powertech Pvt. Ltd. (Sadasivpet)	8.48			
	ACME Rangareddy Solar Power	4.47			
	ACME Solar Power Tech. Pvt. Ltd. (Bhongir)	7.99			
	Azure Power India Pvt. Ltd. (solar)	16.19			
	Clean Hero Wind Power	3.53			
	Clean Solar Power (Chittradurga) Pvt. Ltd	5.39			
	Clean solar	4.50			
	Dayakara Solar (P) Ltd.	4.52			
	Dinakar Solar	3.43			
	Divine Solren Pvt. Ltd.	7.41			
	Dundigal Waste 2 Energy Power Plant	7.20			
	Energon Soleq Solar (Sadasivapet)	6.63			
	Enrich (Solar)	6.85			
	G.S.R.Sugars Pvt Ltd	4.22			
	Ganapathi Sugars Ltd.	0.14			
	Grahati Solar	8.09			
	Hyderabad MSW Energy Solutions PVT LTD	13.57			
	Jilesh Power Pvt. Ltd (Solar)	7.78			
	Kakatiya Cement & Sugar Industries Ltd.	-0.11			
	Karvy Solar Pvt. Ltd. (Sadasivapet)	2.71			
	Karvy solar (Mandamarry)	7.45			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Aakash Power Pvt. Ltd.	7.27			
	Mytrah Agriya Power Pvt. Ltd. (Solar)	7.88			
	Mytrah Agriya Power Pvt. Ltd. (solar) (Kamareddy)	8.33			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	13.52			
	NEO Solren Pvt. Ltd. (solar)	5.60			
	NTPC Solar power plant (10MW)	0.70			
	Nizam Deccan Sugars Ltd	0.00			
	Param Pujya Solar Farms Ltd. Plant-I	8.26			
	Param Pujya Solar Farms Ltd. Plant-II	8.31			
	Polepally Solar Park	3.57			
	Prathamesh solar farms Ltd.	7.98			
	RDF Power Projects Pvt. Ltd.	0.00			
	Renew Mega Solar Pvt.Ltd	7.13			
	Renew Saurshakthi Pvt. Ltd.	3.88			
	Renew Solar Energy Pvt. Ltd. 220kV	19.56			
	Renew Solar Plant (Mdk. Dist.)	3.44			
	Renew Solar Pvt Ltd. (Minpur)	8.73			
	Renew Wind TN2 Solar	15.73			
	Renue Akshay Solar Plant	14.02			
	SLS Power Corp. Ltd. (Minihydel) 132KV	7.91			
	SUZLON Energy Ltd.	15.29			
	Shravana Power Projects Pvt. Ltd.	-0.02			
	Sky Power Southeast Asia III Ltd (Previously Sunshakthi solar pvt. Ltd.)	7.55			
	Sunborne Energy Tech. (P) Ltd. (Solar)	5.60			
	Sunworld Solar Power Pvt. Ltd.	4.71			
	Suprasanna Solar	3.22			
	Suraj Kiran Solar Technologies (Mdk)	7.23			
	Suraj Kiran solar (Nlg)	7.00			
	Suryoday Energy Pvt. Ltd. (Shapoorji Pallonji)(Solar)	5.21			
	Transform Sun Energy 220kV	13.78			
	Ujjvalatejas Solaire Urja Pvt. Ltd. (Solar)	3.13			
	Vena Energy Solar Pvt Ltd (Previously Energon Soleq Pvt Ltd)	7.96			
	Winsol solar (Polepally)	2.34			
	Winsol solar (Tandur)	8.09			
	Zuka Solar	8.93			
IPPs	SINAGARENI	661.89		MU	in %
	TOTAL INPUT	5844.47	Total Losses	128.03	2.19
* Transmission Losses are applicable to OA Users for the period from 00:00 Hrs.of 26th Dec- 2024 to 24:00 Hrs of 25th Jan- 2025					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st November-2024 to 24.00 Hr of 30th November-2024 at 00.15 Hr interval.					
* Cummilative losses at TG-Periphery FY 2024-25 is 2.19 %					